



Department Of Health & Family Welfare

SANITARY FITNESS CERTIFICATE

ശുചിത്വസാക്ഷ്യപത്രം

As per Section (21) of Kerala Public Health Ordinance 2022

FAMILY HEALTH CENTRE.....Taluk/Primary/Family/Community Health Centre

PH: NO. 0495-2282600.....e-mail phcomassery@gmail.com.....

Ref.NO-

Certified that the Building No. 317/E of Omassery.....

Grama Panchayath/Municipality Proposed for

Owned by Manager, Hillview International School, Koodathai -
.....has

Inspected by me and the sanitary arrangements made at present are satisfactory. Hence a certificate of sanitary fitness is issued to run the above establishment subject to the conditions laid down in the Kerala Public Health Ordinance 2022. Any violation of the terms and conditions of the ordinance will automatically invalid this certificate.

This certificate is valid up to 31/3/2025.

Place: Omassery

Date; 6.04.2024.

Signature

HEALTH INSPECTOR
Family Health Centre
Omassery - 673 582





KERALA WATER AUTHORITY

QUALITY CONTROL SUB DISTRICT LAB
MALAPARAMBA, KOZHIKODE

Ph: 0495 2964751

E-mail : qualitysdmalaparamba@gmail.com

TEST REPORT

Report No – KWA/KKD/0405/24


Date of issue: 06/03/2024

HILLVIEW INTERNATIONAL SCHOOL KODATHAI BAZAR PO THAMARASSERRY	1.Date of Receipt	: 04/03/2024
	2. Sample condition	: FIT FOR ANALYSIS
	3.Sampling done by	: PARTY
	4.Sample code	: 0405/24
	5.Source of sample	: OPEN WELL
	6.Sample quantity	: 1LTR
	7.Test performing dates From	: 04/03/2024 To : 06/03/2024


Sl. No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Electrical conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14)-2013 (Reaffirmed 2019)	-	75
2	Acidity	(mg/L)	IS 3025 (part 22)-1986 (Reaffirmed 2019)	-	ND
3	Sulphate (as SO ₄)	(mg/L)	IS 3025 (PART 24)-1986 (Reaffirmed 2019)	200	2.3
4	Phosphate [as PO ₄]	(mg/L)	IS 3025 (PART 31)-2008 (Reaffirmed 2019)	-	BDL
5	Fluoride (as F)	(mg/L)	APHA 4500F-D 23 rd Edition	1.0	ND
6	Iron (as Fe)	(mg/L)	IS 3025 (part 53)-2003 (Reaffirmed 2014)	1.0	BDL
7	Nitrate (as NO ₃)	(mg/L)	APHA 4500NO3-B 23 rd Edition	45	BDL
8	Ammonia	(mg/L)	IS 3025 (part 34)-2008 (Reaffirmed 2019)	0.5	BDL
9	Residual Chlorine	(mg/L)	IS 3025 (part 26)-1986 (Reaffirmed 2019)	0.2	ND

BDL: BELOW DETECTION LEVEL

NB:- The results stated above related only to the samples(S) submitting for testing. This test Certificate shall not be reproduced except in full without the written approval of the Laboratory.

Analyzed By:  Chemist


Authorized By : Deputy Quality Manager



DEPUTY QUALITY MANAGER
KERALA WATER AUTHORITY
SUB DISTRICT LABORATORY
KOZHIKODE